



सी इ पी सी आई प्रयोगशाला
एवं अनुसंधान संस्थान



CEPCI LABORATORY &
RESEARCH INSTITUTE



काश्यू भवन्, मुन्टक्कल, कोललम- 691001, केरल, भारत. CIN:U74999KL1955NPL000300

Cashew Bhavan, Mundakkal, Kollam - 691 001, Kerala, India. Tel: +91 474 2761003, 2742704
Email: cepcilab@cashewindia.org Web: www.cepcilab.org

TEST CERTIFICATE
ORIGINAL

Date : 13 Jun 2025

ULR - TC11801250090189375

No : 1999

CUSTOMER ADDRESS	SAMPLE DETAILS
Name & Address : Sree Narayana Public School,Kizhavor,Mukhathala P.O.,Kollam-691577	Reg.No : CEPC/959/25-26 Customer Reference : Letter Dated 09.06.2025 Sampling details : Direct Identification Code : Sample no-1
Other details if any :	Type of Sample : Well Water Sample Description : Colourless liquid with tiny suspended particles Condition of the sample : Satisfactory Date of Receipt : 09 Jun 2025 Date of Starting : 09 Jun 2025 Date of Completion : 13 Jun 2025 Condition of packing : Unsealed plastic can

Table 1. Organoleptic and physical Parameters

Sl.No	Parameters	Results	Test Methods	Acceptable limit:Drinking water specification- IS 10500 : 2012
I	Odour	Agreeable	IS 3025 (part 5):2018	Agreeable
II	Total dissolved solids ,mg/l	144	IS 3025 (part 16):2023	500
III	pH	5.5@25Deg.C	IS 3025(Part 11)2022	6.5 -8.5
IV	Colour ,Hazen units	Less than 1	IS 3025 (part 4):2021	5

Table 2. General Parameters Concerning Substances Undesirable in Excessive Amounts

Sl.No	Parameters	Results	Test Methods	Acceptable limit:Drinking water specification- IS 10500 : 2012
I	Total Hardness (as CaCO ₃) ,mg/l	56.9	IS 3025 (part 21):2009	200

Note : The test report is as per the details and samples provided to this laboratory in Kollam.



Authorized Signatory
(Chemical)
AJINI. A.S
Senior Scientist

● This Test Certificate refers only to the item tested.

● This certificate, if reproduced, shall only be in full.

● Written approval of the Lab-in-charge is necessary for reproduction of this certificate.



ORIGINAL

Date : 13 Jun 2025

No : 1999

Microbiological Analysis

Sl.No	Parameters	Results	Test Methods	Acceptable limit:Drinking water specification- IS 10500 : 2012
I	Total Coliforms ,Presence/Absence in 100 ml	Present	IS 15185:2016	Absent in 100 ml
II	E.coli ,Presence/Absence in 100 ml	Absent	IS 15185:2016	Absent in 100ml

Note : The test report is as per the details and samples provided to this laboratory in Kollam.

Subi Mathew
Authorized Signatory
(Microbiology)

Dr. SUBI MATHEW
Scientist

